

Wisconsin Public Service Corporation  
and Upper Peninsula Power Company  
Gas & Electric Service Rules  
2010-2012

Table of Contents  
(Web Version)

Introduction

Purpose	1-1
Territory Maps	1-2
Company Phone Numbers, Web Applications	1-3

200 Amp and Smaller - Common

General Metering Requirements	1-4
Basic Calculations	2-1
100-200 Amp Single Phase UG	2-2
100-200 Amp Single Phase UG with Main	2-3
100-200 Amp Single Phase OH	2-4
Temporary Services	2-5
Mobile Home Services	2-6
100-200 Amp Three Phase OH or UG	2-7

400 Amp and Larger - Common

320 Class/400 Amp Single Phase UG	3-1
400/600 Amp Single Phase, Bolt-In	3-2
120/208 Volt 400/600 Amp Three Phase, Bolt-In	3-3
UG CT Cabinets	3-4
Termination Space Requirements	3-5
CT's in Padmounted Transformers	3-6
Termination Enclosures	3-7
Standard Pad for 70-2500 KVA Padmount Transformers	3-8
Protective Posts for Padmount Transformers	3-9
Location of Padmounted Transformers Near Buildings	3-10
Multiple Metering	3-11
Residential Deck Procedure (old 5-2)	3-12
Maximum Fault Currents	3-13
Trouble Shooting Peak Load Interrupters	3-14

Gas Metering

Clearance to Gas Meters	4-1
Meter Size Dimensions	4-2
Meter Protection From Vehicles	4-3
Mobile Home Installation	4-4
Underground Fuel Runs	4-5
Meter Protection From Snow and Ice	4-6