

Available Service Voltages	Electric
<p>1. The Company furnishes 60 hertz alternating current, single and three phase, at various voltages, but not all types of service are available at every location.</p> <p>2. The Company should be consulted as to the type of service available in any area before wiring layouts are made, equipment is purchased, or when extensive wiring changes are contemplated.</p> <p>3. The Company will normally supply to each customer's building, structure or premises:</p> <p>a. One service lateral (drop). b. One class of service. c. One meter.</p> <p><u>Exceptions to this rule are:</u></p> <p>a. Multiple occupancy buildings (e.g., row houses, condominiums) which comply with the Wisconsin State Electrical Code by having areas under different occupancies separated by approved fire walls may be supplied by more than one service.</p> <p>b. Fire pumps or other emergency electrical systems requiring separate service.</p> <p>c. Large or unusual loads requiring additional services or a different class of service in accordance with these "Character of Service" rules.</p> <p>d. Where more than one point of delivery or more than one point of metering is necessary because of interruptible service rate, governmental requirements or regulatory rules (e.g., PSCW Rule 113.0803, which requires separate meters for each dwelling and commercial unit in a multi-dwelling unit residential building, mobile home park, and commercial building constructed after March 1, 1980).</p> <p>e. Cases where, in the judgment of the Company, voltage regulation would be unreasonable due to load size and distance between loads.</p> <p>Continued to Sheet No. E3.11.</p>	

D

R

Issued 1-13-11

Effective for Service Rendered
 On and After 1-14-11

PSCW Authorization By Order 6690-UR-120 Dated 1-13-11

Available Service Voltages	Electric
Continued from Sheet No. E3.10.	
D	4. The types of service and nominal voltages furnished are listed below.
	a. <u>Single Phase, 120/240 Volt, Three Wire</u>
	This service is available to customers whose demand will not exceed 800 amp (200 Kva). This service is not available in areas designated as "120/208 volt areas" or where the customer has an existing service.
	b. <u>Single Phase, 120/208 Volt, Three Wire</u>
	This service is available in areas designated as "120/208 volt areas" and where the demand will be 200 amp (50 Kva) or less. This service is not available where customer has an existing service.
	c. <u>Three Phase, 480 Volt, Three Wire</u>
R	Closed to new customers.
R R R	Existing customers served by an open-delta setting in an area with only two primary phases available, will be allowed to increase their demand up to a maximum of 100 amp (75 Kva).
R R R R	Existing customers in an area with three primary phases available will be allowed to increase their demand at 480 volt, three wire, up to the existing main switch rating, not to exceed a maximum of 3000 amp (2500 Kva).
Continued to Sheet No. E3.12.	

Issued 1-13-11

Effective for Service Rendered
 On and After 1-14-11

PSCW Authorization By Order 6690-UR-120 Dated 1-13-11

Available Service Voltages	Electric
Continued from Sheet No. E3.11.	
4.	d. <u>Combination Single Phase and Three Phase, 120/240 Volt, Four Wire Delta</u>
	Closed to new Customers
	Existing customers with this voltage or 240 volt, 3 phase, 3 wire delta, will be allowed to increase their demand at this voltage at the existing location up to the existing main switch rating, not to exceed 1500 Kva.
	e. <u>Combination Single Phase and Three Phase, 120/208 Volt, Four Wire Wye</u>
R	This service is available to customers where the demand will not exceed 3000 amp (1,000 Kva).
	f. <u>Combination Single Phase and Three Phase, 277/480 Volt, Four Wire Wye</u>
	This service is available to customers where the demand will not exceed 3000 amp (2500 Kva).
	g. <u>Combination Single Phase and Three Phase, 2400/4160 Volt, Four Wire Wye</u>
N	This service is closed to new customers.
Continued to Sheet No. E3.13.	

Issued 12-27-2022

Effective for Service Rendered
 On and After 1-1-2023

PSCW Authorization By Order 6690-UR-127 Dated 12-22-2022

Available Service Voltages	Electric
Continued from Sheet No. E3.12.	
h. <u>Combination Single Phase and Three Phase, 14,400/24,940 Volt, Four Wire Wye</u> This service is available to customers where the demand will exceed 1000 Kva.	
R 5. <u>UNDERGROUND SERVICES FROM A POLE TRANSFORMER</u> R The voltages specified in section 4.1. through 4.f. are available to R customers whose demand will not exceed 800 amp are subject to the R limitations set forth in those rules.	
6. Customer request for additional services or service which does not conform to these rules shall be treated as "special facilities" for which the customer is obligated, in accordance with extension rules, for any added costs involved. The company reserves the right to deny special facilities.	
7. Exceptions to the above rules may be made when clearly warranted due to unusual engineering or economic circumstances.	

Issued 1-13-11

Effective for Service Rendered
 On and After 1-14-11

PSCW Authorization By Order 6690-UR-120 Dated 1-13-11