

D9. PARALLEL GENERATION-PURCHASE BY WPSC

PG-4M

EFFECTIVE IN: All territory served.

AVAILABILITY

To customers contracting for electric service who satisfy the requirements of "qualifying facility" status under Part 292 of the Federal Energy Regulatory Commission's regulations under the Public Utility Regulatory Policies Act of 1978, generating electrical energy with total customer owned generating capacity of **5,000 KW** or less, and desiring to sell electrical energy to the Company. Customers are not required to take electric service deliveries from the Company. Customers shall enter into a five, ten or fifteen year service agreement with the Company. Customers with generation capacity of 5,000 KW or less have the option of selling energy to the Company under this PG-4M tariff or the PG-3M tariff. The Commission's Order in Case No. U-21081 determined that the Company did not have a capacity need; therefore, no capacity payment will be payable to systems eligible for this tariff.

NEGOTIATED RATES

Parallel generation customers have the right to request negotiated buy back rates. The following are the required procedure guidelines:

1. Except as allowed by Paragraph 3 below, the Company must respond to the customer owned generating system within 30 days of the initial receipt of the customer owned generating system written proposal, and within 30 days of receipt of any subsequent customer owned generating system written proposal;
2. The Company's rejection of the customer owned generating system written proposal must be accompanied by a counter offer relating to the specific subject matter of the customer owned generating system written proposal; and
3. If the Company is unable to respond to the customer owned generating system written proposal within 30 days it shall inform the customer owned generating system of:
 - a. Specific information needed to evaluate the customer owned generating system proposal.
 - b. The precise difficulty encountered in evaluating the customer owned generating system written proposal.
 - c. The estimated date that it will respond to the customer owned generating system written proposal.
4. The commission may become involved in the Company negotiations upon showing by either the Company or the customer owned generating system that a reasonable conclusion cannot be reached under the above guidelines. The commission may provide a waiver to the guidelines and order new negotiation requirements so that a reasonable conclusion can be reached.

Renewable Premium

At the Company's sole discretion, a premium to be paid on a per kWh basis may be applied to generators that generate a renewable credit that is transferred to the Company. Customers retain the right to refuse a renewable premium and keep the renewable credits or tags.


SPECIAL RULES

1. The Company shall install appropriate metering facilities to record all flows of energy necessary to bill the customer in accordance with the charges and credits of this rate schedule.
2. The customer shall furnish, install, and wire the necessary service entrance equipment, meter sockets, meter enclosure cabinets, or meter connection cabinets that may be required by the Company to properly meter usage and sales to the Company.
3. The requirements for interconnecting a generator with the Company's facilities are contained in the Michigan Public Service Commission's Electric Interconnection Standards Rules ([R460.481- 460.489](#)) and the Company's Michigan Utility Generator Interconnection Requirements, copies of which will be provided to customers upon request. All requirements must be met prior to commencing service.

PARALLEL GENERATION RULES

See Schedule PGXM.

Issued September 30, 2022
T. T. Eidukas
Vice-President,
Milwaukee, Wisconsin



Effective for service rendered on and after September 21, 2022

Issued under authority of the Michigan Public Service Commission
Dated May 12, 2022
in Case No. U-21081

D9. PARALLEL GENERATION-RULES

PGXM

PARALLEL GENERATION RULES

The following rules shall apply to all customer owned generation facilities that are interconnected with the company's power supply:

1. Interconnection of a generating facility with the company shall not be permitted until application has been made to and approval received from the company. The company may withhold approval for good reason such as failure to comply with applicable utility or governmental rules or laws. The company shall require a contract specifying reasonable technical connection and operating aspects for the parallel generating facility.
2. The company may require that for each generating facility there be provided between the generator or generators and the company system a lockable load-break disconnect switch. For installations interconnected at greater than 600 volts a fused cutout switch may be substituted, where practicable. The switches shall be accessible to the company for the purpose of isolating the parallel generating facility from the company system when necessary.
3. The company shall require a separate distribution transformer for a customer having a generating facility where necessary, for reasons of public or employee safety or where the potential exists for the generating facility causing problems with the service of other customers. Ordinarily this requirement should not be necessary for an induction-type generator with a capacity of 5 Kw or less, or other generating units of 10 Kw or less that utilize line-commutated inverters.
4. Where necessary, to avoid the potential for a facility causing problems with the service of other customers, the company shall limit the capacity and operating characteristics of single-phase generators in a manner consistent with its existing limitations for single-phase motors. Ordinarily single-phase generators should be limited to a capacity of 10 Kw or less.
5. The company shall require that each generating facility have a system for automatically isolating the generator from the company's system upon loss of the company supply, unless the company desires that the local generation be continued to supply isolated load. For synchronous and induction generators such protection against continued operation when isolated from the company system will ordinarily consist of overcurrent protection, fuse or circuit breaker, plus a voltage or frequency controlled contactor which would automatically disconnect the unit whenever its output voltage or frequency drifted outside predetermined limits, such as plus or minus 10% of the rated values. Other suitable protective systems against abnormal voltages or frequencies may be accepted by the company.
6. The company shall require that the customer discontinue parallel generation operation when it so requests and the company may isolate the generating installation from its system at times:
 - a. When considered necessary to facilitate maintenance or repair of company facilities.
 - b. When considered necessary during system emergencies.
 - c. When considered necessary during such times as the generating facility is operating in a hazardous manner, or is operating such that it adversely affects service to other customers or to nearby communication systems or circuits.
7. The owner of the generating facility shall be required to make the equipment available and permit entry upon the property by company and communication utility personnel at reasonable times for the purposes of testing isolation and protective equipment, and evaluating the quality of power delivered to the company's system; and testing to determine whether the local generating facility is the source of any electric service or communication systems problems.
8. The power output of the generating facility shall be maintained such that frequency and voltage are compatible with normal company service and do not cause that company service to fall outside the prescribed limits of commission rules and other standard limitations.
9. The generating facility shall be operated so that variations from acceptable voltage levels and other service impairing disturbances do not result in adverse effects on the service or equipment of other customers, and in a manner which does not produce undesirable levels of harmonics in the company power supply.

(Continued on Sheet No. D-150.00)

Issued December 21, 2016
T. T. Eidukas
Vice-President,
Milwaukee, Wisconsin



Effective for service rendered on and after January 1, 2017

Issued under authority of the Michigan Public Service Commission dated December 9, 2016 in Case No. U-18061

D9. PARALLEL GENERATION-RULES

PGXM

(Continued from Sheet No. D-149.00)

PARALLEL GENERATION RULES (Cont.)

10. The owner of the generating facility shall be responsible for providing protection for the owner's installed equipment and for adhering to all applicable national, state and local codes. The design and configuration of certain generating equipment such as that utilizing line-commutated inverters sometimes requires an isolation transformer as part of the generating installation for safety and for protection of the generating facilities.
11. The owner of a generating facility interconnected or proposed to be interconnected with the Company system may appeal to the commission should any requirement of the Company service rules filed in accordance with the provisions of PSC 113.70 be considered to be excessive or unreasonable. Such appeal will be reviewed and the customer notified of the commission's determination.
12. The Company will notify telephone utility and cable television firms in the area when it knows that customer-owned generating facility is to be interconnected with its system. This notification shall be as early as practicable to permit coordinated analysis and testing in advance of interconnection, if considered necessary by the electric or telephone utility or cable television firm.
13. The owner of the generating facility shall be required to pay all interconnection costs, including any metering transformers, incurred by the Company. Said costs, including financing costs, shall be paid by the owner within two years of the installation date of the interconnection facilities.
14. The owner of the generating facility shall be required to have liability insurance on the generating facility of at least \$100,000 or be able to prove financial responsibility.
15. Electric service to a customer owned electric generation installation may be disconnected for failure to comply with these parallel generation rules.
16. *The Company may purchase renewable energy credits (RECs) from qualifying facilities (QFs).*

Issued January 2, 2019
T. T. Eidukas
Vice-President,
Milwaukee, Wisconsin



Effective for service rendered on and after January 1, 2019

Issued under authority of the
Michigan Public Service Commission
Dated December 20, 2018
in Case Nos. U-18095 and 18096